

No.: IN-SH-CP-5627-24072

Applicant: CORONET GROUP SUZHOU CO., LTD.

Address: ASCENDAS XINSU SQUARE, 5 XINGHAN STREET, SUZHOU, JIANGSU, CHINA

Manufacturer: Q/IN-SH-CP-5627-24028

It has been verified that

Product(s): RINGLOCK SCAFFOLD

Specification: See the next page

Material: Q345

are submitted by the applicant to the testing of the product in accordance with the applicant's requirements. The product is deemed to be in conformity with the requirements of EN 12811-1:2003 clause 6.2.2.2, clause 6.2.2.3 on basis of the test report of SHIN2401000072CM02_EN

This verification is valid from 29 February 2024 until 28 February 2027 and remains valid as long as the manufacturing

Conditions in the plant and the factory production control itself are not modified significantly.

Issue 1. This verification was first issued on 29 February 2024

Authorised by

Lisa Liang

Manager

Industries Service - CP Certification

SGS-CSTC Standards Technical Services Co., Ltd.

16F Century Yuhui Mansion, No.73 Fucheng Road, Haidian District, Beijing, China 100142

email CN.CONSTProdcert@sgs.com website www.sgs.com



SGSSGSGSTATE

Disclaimer: Neither SGS-CSTC, any of it affiliated SGS sister organizations nor the SGS Group can be held responsibly for conformity or non-conformity of the actual product with the contents of the Technical File. Copyright of this verification is owned by SGS-CSTC IND Services and may not be reproduced other than in full.

Page 1 of 6 VOC-01



No.: IN-SH-CP-5627-24072 continued

Product specifications are shown as following:

| Reference Number | Product Specification | | |
|------------------|-------------------------|--|--|
| RV99 | Ring lock Standard 3.0m | | |
| RV66 | Ringlock Standard 2.0m | | |
| RV33 | Ringlock Standard 1.0m | | |
| RH307 | Ringlock Ledger 3.07m | | |
| RH257 | Ringlock Ledger 2.57m | | |
| RH207 | Ringlock Ledger 2.07m | | |
| RH157 | Ringlock Ledger 1.57m | | |
| RH140 | Ringlock Ledger 1.40m | | |
| RH109 | Ringlock Ledger 1.09m | | |
| RH073 | Ringlock Ledger 0.73m | | |

Issue 1. This verification was first issued on 29 February 2024

Authorised by

Lisa Liang

Manager



No.: IN-SH-CP-5627-24072 continued

Product specifications are shown as following:

| Reference Number | Product Specification | | |
|------------------|---------------------------------|--|--|
| ROSP32073 | Ringlock Steel Plank 3.07x0.32m | | |
| ROSP32257 | Ringlock Steel Plank 2.57x0.32m | | |
| ROSP32207 | Ringlock Steel Plank 2.07x0.32m | | |
| ROSP32157 | Ringlock Steel Plank 1.57x0.32m | | |
| ROSP32140 | Ringlock Steel Plank 1.40x0.32m | | |
| ROSP32109 | Ringlock Steel Plank 1.09x0.32m | | |
| ROSP32073 | Ringlock Steel Plank 0.73x0.32m | | |
| RTB207 | Ringlock Steel Toeboard 2.07m | | |
| RTB109 | Ringlock Steel Toeboard 1.09m | | |
| CSJB600 | Ringlock Base Jack 600mm | | |
| RSC-L | Ringlock Base Collar 310mm | | |

Issue 1. This verification was first issued on 29 February 2024

Authorised by

Lisa Liang

Manager



No.: IN-SH-CP-5627-24072 continued

Results of examinations are as following:

| Test Items | Test Method | Test Span(mm) | Requirements | Results | Verdict |
|---|-------------|--|---|---|---------|
| Uniformly EN Distributed 12811-1:2003 Service Load Clause 6.2.2.2 | | 730 | | The working area could support the uniformly distributed load | Pass |
| | | 1090 | | The working area could support the uniformly distributed load | Pass |
| | | 1400 | | The working area could support the uniformly distributed load | Pass |
| | 1570 | The working area shall be capable of supporting the uniformly distributed load | The working area could support the uniformly distributed load | Pass | |
| | 2070 | | The working area could support the uniformly distributed load | Pass | |
| | 2570 | | The working area could support the uniformly distributed load | Pass | |
| | 3070 | | The working area could support the uniformly distributed load | Pass | |

Issue 1. This verification was first issued on 29 February 2024

Authorised by

Lisa Liang

Manager



No.: IN-SH-CP-5627-24072 continued

| Test Items | Test Method | Test Span(mm) | Requirements | Results | Verdict |
|---|----------------|--|---|---|---------|
| Concentrated Load on Area 200mm × 200mm 6.2.2.3 | | 730 | The platform can support the concentrated load on area 200mm × 200mm in the most | The platform could support the concentrated load on area 200mm × 200mm in the most unfavorable position and the deformation of the platform is 1.85mm. | Pass |
| | | 1090 | | The platform could support the concentrated load on area 200mm × 200mm in the most unfavorable position and the deformation of the platform is 2.08 mm. | Pass |
| | | unfavorable position and the deformation of platform shall not exceed 1/100 of its span. | The platform could support the concentrated load on area 200mm × 200mm in the most unfavorable position and the deformation of the platform is 1.85 mm. | Pass | |
| | | 1570 | | The platform could support the concentrated load on area 200mm × 200mm in the most unfavorable position and the deformation of the platform is 1.43 mm. | Pass |

Results of examinations are as following:

Issue 1. This verification was first issued on 29 February 2024

Authorised by

Lisa Liang

Manager



No.: IN-SH-CP-5627-24072 continued

Results of examinations are as following:

| Test Items | Test Method | Test Span(mm) | Requirements | Results | Verdict |
|---|----------------|--|---|--|---------|
| Concentrated Load on Area 200mm × 200mm 6.2.2.3 | | 2070 | The platform can | The platform could support the concentrated load on area 200mm × 200mm in the most unfavorable position and the deformation of the platform is 3.87mm. | Pass |
| | 2570 | support the concentrated load on area 200mm × 200mm in the most unfavorable position and the deformation of platform shall not exceed 1/100 of its span. | The platform could support the concentrated load on area 200mm × 200mm in the most unfavorable position and the deformation of the platform is 4.26 mm. | Pass | |
| | 3070 | | The platform could support the concentrated load on area 200mm × 200mm in the most unfavorable position and the deformation of the platform is 6.10 mm. | Pass | |

Statement: Unless

otherwise stated the results shown in this verification refer only to the sample(s) tested. The manufacturer is obligated to guarantee stability of product performance.

Issue 1. This verification was first issued on 29 February 2024

Authorised by

Lisa Liang

Manager